




574 WEST OTTERMAN STREET POST OFFICE BOX 70 GREENSBURG, PA 15601-0070 TELEPHONE: 724-834-7300

ΓELEPHONE: 724-834-7300 FAX: 724-830-2871


MODEL NO. 5292272 / STC 52 / DUAL GLAZED / SOUND CONTROL FIXED WINDOW ASSEMBLY / NEOPRENE GLAZING




ELEVATION

NOTES:

- 1. All exposed surfaces of frame to receive one coat of rust inhibitive prime paint.
- 2. Unit weight, including frame, glass, and glazing, is 12.5 pounds per square foot.
- Frames equipped with masonry anchors must be grouted full in field. Bolt-in type frames must have all voids in head, jambs, and sill packed with 6 to 12 pound density mineral wool.
- 4. Unit may be provided with two (2) optional purge ports.
- 5. Unit can be UL Fire Labeled and remain acoustically certified when it is glazed with one pane of Acousta-Pane 36, 1/4" laminated glass and one pane of up to 5/16" thick UL listed glass such as FireLite brand Ceramic glass.
- All voids between wall and frame must be continuously caulked



HORIZONTAL SECTION



VERTICAL SECTION

	SOUND TRANSMISSION LOSS IN dB AT FREQUENCY / HERTZ																	
100) 12	5	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000
28	37	7	32	37	39	43	46	50	52	55	56	58	60	61	61	63	66	68